

	<p>Public Notification of Bypass, Overflow and Spill Events</p>	<p>Issued: 2024-09-04 Rev.: 2 Pages: 1 of 1</p>
<p>Wasaga Beach Wastewater Treatment Plant</p>		

Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 0766-CM9RQA issued February 16, 2023 for the Wasaga Beach Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

Details

Location:	Wasaga Beach WPCP
Type of Event:	<input type="checkbox"/> Overflow <input checked="" type="checkbox"/> Bypass <input type="checkbox"/> Spill
Start Date & Time:	February 19, 2025 @ 0715 hrs
End Date & Time:	February 19, 2025 @ 0719 hrs
Total Discharge Volume (m³):	5.5
Cause of the Event:	<p>OCWA Operations staff responded to an alarm at the WPCP and found a tertiary filter in an alarm state and bypassing. A second filter was online and in operation, in addition, all effluent received UV disinfection treatment. Operations staff have identified the issue and are making progress towards fixing the root cause. The bypass has ceased and all operations has returned to normal.</p>

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.